

SCHEDULE 9

Marine Licence 2: Project B Offshore Generation – Work Nos. 1B and 2T

PART 2

Conditions

Detailed offshore design parameters

7. Within Work No. 1B, the wind turbine generator foundations must not have—
 - (a) a total seabed footprint exceeding 1,005,300 square metres;
 - (b) subsea scour protection exceeding 1,084,850 cubic metres in total volume of material;
 - (c) subsea scour protection exceeding 755,400 square metres in total seabed footprint.