

## SCHEDULE 2

### REQUIREMENTS FOR WATER FITTINGS

#### *Baths, sinks, showers and taps*

**26.** All premises supplied with water for domestic purposes shall have at least one tap conveniently situated for the drawing of drinking water.

**27.** A drinking water tap shall be supplied with water from—

- (a) a supply pipe;
- (b) a pump delivery pipe drawing water from a supply pipe; or
- (c) a distributing pipe drawing water exclusively from a storage cistern supplying wholesome water.

**28.—(1)** Subject to paragraph (2), every bath, wash basin, sink or similar appliance shall be provided with a watertight and readily accessible plug or other device capable of closing the waste outlet.

(2) This requirement does not apply to—

- (a) an appliance where the only taps provided are spray taps;
- (b) a washing trough or wash basin whose waste outlet is incapable of accepting a plug and to which water is delivered at a rate not exceeding 0.06 litres per second exclusively from a fitting designed or adapted for that purpose;
- (c) a wash basin or washing trough fitted with self-closing taps;
- (d) a shower bath or shower tray;
- (e) a drinking water fountain or similar facility; or
- (f) an appliance which is used in medical, dental or veterinary premises and is designed or adapted for use with an unplugged outlet.