

## **SCHEDULE 2**

### **REQUIREMENTS FOR WATER FITTINGS**

#### *Requirements for water fittings*

- 7.—(1) No water fitting shall be embedded in any wall or solid floor.
- (2) No fitting which is designed to be operated or maintained, whether manually or electronically, or which consists of a joint, shall be a concealed water fitting.
- (3) Any concealed water fitting or mechanical backflow prevention device, not being a terminal fitting, shall be made of gunmetal, or another material resistant to dezincification.
- (4) Any water fitting laid below ground level shall have a depth of cover sufficient to prevent water freezing in the fitting.
- (5) In this paragraph “concealed water fitting” means a water fitting which—
- (a) is installed below ground;
  - (b) passes through or under any wall, footing or foundation;
  - (c) is enclosed in any chase or duct; or
  - (d) is in any other position which is inaccessible or renders access difficult.