

**Changes to legislation:** There are outstanding changes not yet made by the legislation.gov.uk editorial team to The Water Supply (Water Quality) (Scotland) Regulations 2001. Any changes that have already been made by the team appear in the content and are referenced with annotations. (See end of Document for details) View outstanding changes

## SCHEDULE 3

## MONITORING

## TABLE 4

## ANNUAL SAMPLING FREQUENCIES: WATER TREATMENT WORKS

<b>(1)</b> <b>Item</b>	<b>(2)</b> <b>Substances and parameters subject to check monitoring</b>	<b>(3)</b> <b>Volume of water supplied m<sup>3</sup>/d</b>	<b>(4)</b> <b>Reduced</b>	<b>(5)</b> <b>Standard</b>
1.	<i>E. coli</i>	<20		4
2.	Coliform bacteria	20 – 1,999	12	52
3.	Colony counts	2,000 – 5,999	52	104
4.	Residual disinfectant	6,000 – 11,999	104	208
		.12,000	104	365
5.	Nitrite {s022}	<20		2
6.	Turbidity	20 – 999	2	4
		1,000 – 1,999	6	12
		2,000 – 5,999	12	24
		6,000 – 9,999	18	36
		10,000 – 15,999	26	52
		16,000 – 32,999	52	104
		33,000 – 49,999	78	156
		50,000 – 67,999	104	208
		68,000 – 84,999	130	260
		85,000 – 101,999	156	312
		102,000 – 119,999	183	365
		120,000 – 241,999	365	730
		242,000 – 484,999	730	1,460
		485,000 – 728,999	1,095	2,190

Notes:

{s022} check monitoring at treatment works is required only when chloramination is practised. In other circumstances, audit monitoring is required.

**Changes to legislation:** There are outstanding changes not yet made by the legislation.gov.uk editorial team to The Water Supply (Water Quality) (Scotland) Regulations 2001. Any changes that have already been made by the team appear in the content and are referenced with annotations. (See end of Document for details) [View outstanding changes](#)

		<i>Substances and parameters subject to audit monitoring</i>	
7.	Nitrite {s022}	<20	1
		20 – 999	4
		1,000 – 49,999	8
		50,000 – 89,999	12
		90,000 – 299,999	24
		300,000 – 649,999	36
		650,000	48

---

Notes:

{s022} check monitoring at treatment works is required only when chloramination is practised. In other circumstances, audit monitoring is required.

---

**Changes to legislation:**

There are outstanding changes not yet made by the legislation.gov.uk editorial team to The Water Supply (Water Quality) (Scotland) Regulations 2001. Any changes that have already been made by the team appear in the content and are referenced with annotations.

[View outstanding changes](#)

**Changes and effects yet to be applied to :**

- Regulations revoked by [S.S.I. 2014/364 reg. 50\(1\)\(b\)](#)

**Changes and effects yet to be applied to the whole Instrument associated Parts and Chapters:**

Whole provisions yet to be inserted into this Instrument (including any effects on those provisions):

- reg. 17(2)(aa) inserted by [S.S.I. 2010/95 reg. 7\(2\)](#)
- reg. 17(5)(aa) inserted by [S.S.I. 2010/95 reg. 7\(3\)\(c\)](#)
- reg. 17(5A) inserted by [S.S.I. 2010/95 reg. 7\(4\)](#)
- reg. 18(1)(aa) inserted by [S.S.I. 2010/95 reg. 8\(2\)\(b\)](#)
- reg. 18(2)(c) and word inserted by [S.S.I. 2010/95 reg. 8\(3\)\(e\)](#)
- reg. 18(2)(aa) inserted by [S.S.I. 2010/95 reg. 8\(3\)\(d\)](#)
- reg. 18(2A) inserted by [S.S.I. 2010/95 reg. 8\(4\)](#)
- reg. 18A inserted by [S.S.I. 2010/95 reg. 9](#)
- reg. 25(1A) inserted by [S.S.I. 2010/95 reg. 13](#)
- regs 36–38 Sch 5 Sch 6 rev (25.12.2003) by [S.S.I. 2001/207 reg 39\(1\)\(e\)](#)