

ANNEX II

MINIMUM HEALTH AND SAFETY REQUIREMENTS FOR WORKPLACES ALREADY IN USE, AS REFERRED TO IN ARTICLE 4 OF THE DIRECTIVE

6. Ventilation of enclosed workplaces

Steps shall be taken to see to it that there is sufficient fresh air in enclosed workplaces, having regard to the working methods used and the physical demands placed on the workers.

If a forced ventilation system is used, it shall be maintained in working order.

Any breakdown must be indicated by a control system where this is necessary for the workers' health.