

[^{F1}ANNEX II

MONITORING

Textual Amendments

- F1** Substituted by [Commission Directive \(EU\) 2015/1787 of 6 October 2015 amending Annexes II and III to Council Directive 98/83/EC on the quality of water intended for human consumption.](#)

PART D

Sampling methods and sampling points

2. Sampling at the point of compliance shall meet the following requirements:
 - (a) compliance samples for certain chemical parameters (in particular copper, lead and nickel) shall be taken at the consumer's tap without prior flushing. A random daytime sample of one litre volume is to be taken. As an alternative, Member States may use fixed stagnation time methods that better reflect their national situation, provided that, at the supply zone level, this does not result in fewer cases of non-compliance than using the random daytime method;
 - (b) compliance samples for microbiological parameters at the point of compliance shall be taken and handled according to EN ISO 19458, sampling purpose B.]