

[^{X1}ANNEX I

Safety measures as referred to in Article 3

Editorial Information

- X1** Substituted by [Corrigendum to Directive 2004/54/EC of the European Parliament and of the Council of 29 April 2004 on minimum safety requirements for tunnels in the trans-European road network \(Official Journal of the European Union L 167 of 30 April 2004\)](#).

2.18. Fire resistance of equipment

The level of fire resistance of all tunnel equipment shall take into account the technological possibilities and aim at maintaining the necessary safety functions in the event of a fire.]