

ANNEX V

Technical provisions relating to combustion plants

PART 2

Emission limit values for combustion plants referred to in Article 30(3)

5. Gas turbines (including CCGT) using light and middle distillates as liquid fuels shall be subject to an emission limit value for NO_x of 50 mg/Nm³ and for CO of 100 mg/Nm³

Gas turbines for emergency use that operate less than 500 operating hours per year are not covered by the emission limit values set out in this point. The operator of such plants shall record the used operating hours.