

ANNEX V

Technical provisions relating to combustion plants

PART 3

Emission monitoring

10. The validated hourly and daily average values shall be determined from the measured valid hourly average values after having subtracted the value of the confidence interval specified in point 9.

Any day in which more than three hourly average values are invalid due to malfunction or maintenance of the automated measuring system shall be invalidated. If more than 10 days over a year are invalidated for such situations the competent authority shall require the operator to take adequate measures to improve the reliability of the automated measuring system.