

## ANNEX V

### Technical provisions relating to combustion plants

#### PART 3

##### **Emission monitoring**

2. The competent authority may decide not to require the continuous measurements referred to in point 1 in the following cases:
  - (a) for combustion plants with a life span of less than 10 000 operational hours;
  - (b) for SO<sub>2</sub> and dust from combustion plants firing natural gas;
  - (c) for SO<sub>2</sub> from combustion plants firing oil with known sulphur content in cases where there is no waste gas desulphurisation equipment;
  - (d) for SO<sub>2</sub> from combustion plants firing biomass if the operator can prove that the SO<sub>2</sub> emissions can under no circumstances be higher than the prescribed emission limit values.