

## ANNEX V

## Technical provisions relating to combustion plants

## PART 3

**Emission monitoring**

9. At the emission limit value level, the values of the 95 % confidence intervals of a single measured result shall not exceed the following percentages of the emission limit values:

Carbon monoxide	10 %
Sulphur dioxide	20 %
Nitrogen oxides	20 %
Dust	30 %