

## ANNEX V

### Technical provisions relating to combustion plants

#### PART 4

##### **Assessment of compliance with emission limit values**

2. Where continuous measurements are not required, the emission limit values set out in Parts 1 and 2 shall be regarded as having been complied with if the results of each of the series of measurements or of the other procedures defined and determined according to the rules laid down by the competent authorities do not exceed the emission limit values.