

ANNEX V

Technical provisions relating to combustion plants

PART 5

Minimum rate of desulphurisation

1. Minimum rate of desulphurisation for combustion plants referred to in Article 30(2)

Total rated thermal input (MW)	Minimum rate of desulphurisation	
	Plants which were granted a permit before 27 November 2002 or the operators of which had submitted a complete application for a permit before that date, provided that the plant was put into operation no later than 27 November 2003	Other plants
50-100	80 %	92 %
100-300	90 %	92 %
> 300	96 % ^a	96 %

a For combustion plants firing oil shale, the minimum rate of desulphurisation is 95 %.

2. Minimum rate of desulphurisation for combustion plants referred to in Article 30(3)

Total rated thermal input (MW)	Minimum rate of desulphurisation
50-100	93 %
100-300	93 %
> 300	97 %