

## ANNEX V

## Technical provisions relating to combustion plants

## PART 5

**Minimum rate of desulphurisation**

1. Minimum rate of desulphurisation for combustion plants referred to in Article 30(2)

<b>Total rated thermal input (MW)</b>	<b>Minimum rate of desulphurisation</b>	
	<b>Plants which were granted a permit before 27 November 2002 or the operators of which had submitted a complete application for a permit before that date, provided that the plant was put into operation no later than 27 November 2003</b>	<b>Other plants</b>
50-100	80 %	92 %
100-300	90 %	92 %
> 300	96 % <sup>a</sup>	96 %

**a** For combustion plants firing oil shale, the minimum rate of desulphurisation is 95 %.

2. Minimum rate of desulphurisation for combustion plants referred to in Article 30(3)

<b>Total rated thermal input (MW)</b>	<b>Minimum rate of desulphurisation</b>
50-100	93 %
100-300	93 %
> 300	97 %