

ANNEX II

MONITORING OF RADIOACTIVE SUBSTANCES

3. Tritium

Member States shall ensure that monitoring of tritium in water intended for human consumption is carried out where an anthropogenic source of tritium or other artificial radionuclides is present within the catchment area and it cannot be shown on the basis of other surveillance programmes or investigations that the level of tritium is below the parametric value listed in Annex I. Where monitoring for tritium is required, it shall be carried out at the frequencies indicated in the table appearing in point 6 of this Annex. If the concentration of tritium exceeds its parametric value, an investigation of the presence of other artificial radionuclides shall be required.