

Changes to legislation: There are outstanding changes not yet made to Commission Delegated Regulation (EU) No 1292/2014. Any changes that have already been made to the legislation appear in the content and are referenced with annotations. (See end of Document for details) View outstanding changes

ANNEX **U.K.**

| Product ^{ag} | Product detail ^d | Minimum mean density ^e (kg/m ³) | Minimum overall thickness (mm) | End use condition | Class for floorings ^c |
|---------------------------|--|--|--------------------------------|------------------------------------|----------------------------------|
| Wood flooring | Solid wood flooring of pine or spruce | Pine: 480 Spruce: 400 | 14 | Without air gap underneath | D _{fl} -s1 |
| Wood flooring | Solid flooring of beech, oak, pine or spruce | Beech: 700 Oak: 700 Pine: 430 Spruce: 400 | 20 | With or without air gap underneath | D _{fl} -s1 |
| Wood parquet | Solid wood (one layer) parquet of walnut | 650 | 8 | Glued to substrate ^f | D _{fl} -s1 |
| Wood parquet | Solid (one layer) parquet of oak, maple or ash | Ash: 650 Maple: 650 Oak: 720 | 8 | Glued to substrate ^f | D _{fl} -s1 |
| Wood parquet | Multilayer parquet with oak top layer, at least 3,5 mm | 550 | 15 ^b | Without air gap underneath | D _{fl} -s1 |
| Wood flooring and parquet | Solid wood flooring and parquet not specified above | 400 | 6 | All | E _{fl} |

a Mounted in accordance with EN ISO 9239-1, on a substrate of at least Class D-s2, d0 with minimum density of 400 kg/m³ or with an air gap (minimum height 30 mm) underneath.

b An interlayer of at least Class E_{fl} and with maximum thickness 3 mm and minimum density of 280 kg/m³ may be included.

c Class as set out in Table 2 of the Annex to Decision 2000/147/EC.

d Without surface coatings.

e Conditioned in accordance with EN 13238 (50 % RH, 23 °C).

f Substrate at least Class D-s2, d0.

g Applies also to steps of stairs.

Changes to legislation:

There are outstanding changes not yet made to Commission Delegated Regulation (EU) No 1292/2014. Any changes that have already been made to the legislation appear in the content and are referenced with annotations.

[View outstanding changes](#)

Changes and effects yet to be applied to the whole legislation item and associated provisions

- Signature modified by [S.I. 2019/465 Sch. 3 para. 7](#)