

Regulation (EU) No 517/2014 of the European Parliament and of the Council of 16 April 2014 on fluorinated greenhouse gases and repealing Regulation (EC) No 842/2006 (Text with EEA relevance)

CHAPTER II

CONTAINMENT

Article 3

Prevention of emissions of fluorinated greenhouse gases

1 The intentional release of fluorinated greenhouse gases into the atmosphere shall be prohibited where the release is not technically necessary for the intended use.

2 Operators of equipment that contains fluorinated greenhouse gases shall take precautions to prevent the unintentional release ('leakage') of those gases. They shall take all measures which are technically and economically feasible to minimise leakage of fluorinated greenhouse gases.

3 Where a leakage of fluorinated greenhouse gases is detected, the operators shall ensure that the equipment is repaired without undue delay.

Where the equipment is subject to leak checks under Article 4(1), and a leak in the equipment has been repaired, the operators shall ensure that the equipment is checked by a certified natural person within one month after the repair to verify that the repair has been effective.

4 Natural persons carrying out the tasks referred to in points (a) to (c) of Article 10(1) shall be certified in accordance with Article 10(4) and (7) and shall take precautionary measures to prevent leakage of fluorinated greenhouse gases.

Undertakings carrying out the installation, servicing, maintenance, repair or decommissioning of the equipment listed in points (a) to (d) of the Article 4(2) shall be certified in accordance with Article 10(6) and (7) and shall take precautionary measures to prevent leakage of fluorinated greenhouse gases.