

**Status:** Point in time view as at 31/12/2020.

**Changes to legislation:** There are outstanding changes not yet made to Commission Regulation (EU) 2016/1388. Any changes that have already been made to the legislation appear in the content and are referenced with annotations. (See end of Document for details)

## ANNEX I U.K.

### Frequency ranges and time periods referred to in Article 12(1)

Synchronous area	Frequency range	Time period for operation
<b>Continental Europe</b>	47,5 Hz-48,5 Hz	To be specified by each TSO, but not less than 30 minutes
	48,5 Hz-49,0 Hz	To be specified by each TSO, but not less than the period for 47,5 Hz-48,5 Hz
	49,0 Hz-51,0 Hz	Unlimited
	51,0 Hz-51,5 Hz	30 minutes
<b>Nordic</b>	47,5 Hz-48,5 Hz	30 minutes
	48,5 Hz-49,0 Hz	To be specified by each TSO, but not less than 30 minutes
	49,0 Hz-51,0 Hz	Unlimited
	51,0 Hz-51,5 Hz	30 minutes
<b>Great Britain</b>	47,0 Hz-47,5 Hz	20 seconds
	47,5 Hz-48,5 Hz	90 minutes
	48,5 Hz-49,0 Hz	To be specified by each TSO, but not less than 90 minutes
	49,0 Hz-51,0 Hz	Unlimited
	51,0 Hz-51,5 Hz	90 minutes
	51,5 Hz-52,0 Hz	15 minutes
<b>Ireland and Northern Ireland</b>	47,5 Hz-48,5 Hz	90 minutes
	48,5 Hz-49,0 Hz	To be specified by each TSO, but not less than 90 minutes
	49,0 Hz-51,0 Hz	Unlimited
	51,0 Hz-51,5 Hz	90 minutes
<b>Baltic</b>	47,5 Hz-48,5 Hz	To be specified by each TSO, but not less than 30 minutes
	48,5 Hz-49,0 Hz	To be specified by each TSO, but not less than the period for 47,5 Hz-48,5 Hz
	49,0 Hz-51,0 Hz	Unlimited
	51,0 Hz-51,5 Hz	To be specified by each TSO, but not less than 30 minutes

The table shows the minimum time periods for which a transmission-connected demand facility, a transmission-connected distribution facility or a distribution system has to be capable of

*Status: Point in time view as at 31/12/2020.**Changes to legislation: There are outstanding changes not yet made to Commission Regulation (EU) 2016/1388. Any changes that have already been made to the legislation appear in the content and are referenced with annotations. (See end of Document for details)*

operating on different frequencies, deviating from a nominal value, without disconnecting from the network.

ANNEX II **U.K.****Voltage ranges and time periods referred to in Article 13(1)**

<b>Synchronous area</b>	<b>Voltage range</b>	<b>Time period for operation</b>
<b>Continental Europe</b>	0,90 pu-1,118 pu	Unlimited
	1,118 pu-1,15 pu	To be specified by each TSO but not less than 20 minutes and not more than 60 minutes
<b>Nordic</b>	0,90 pu-1,05 pu	Unlimited
	1,05 pu-1,10 pu	60 minutes
<b>Great Britain</b>	0,90 pu-1,10 pu	Unlimited
<b>Ireland and Northern Ireland</b>	0,90 pu-1,118 pu	Unlimited
<b>Baltic</b>	0,90 pu-1,118 pu	Unlimited
	1,118 pu-1,15 pu	20 minutes

The table shows the minimum time periods during which a transmission-connected demand facility, a transmission-connected distribution facility or a transmission-connected distribution system has to be capable of operating for voltages deviating from the reference 1 pu value at the connection point without disconnecting from the network where the voltage base for pu values is at or above 110 kV and up to (not including) 300 kV.

<b>Synchronous area</b>	<b>Voltage range</b>	<b>Time period for operation</b>
<b>Continental Europe</b>	0,90 pu-1,05 pu	Unlimited
	1,05 pu-1,10 pu	To be specified by each TSO but not less than 20 minutes and not more than 60 minutes
<b>Nordic</b>	0,90 pu-1,05 pu	Unlimited
	1,05 pu-1,10 pu	To be specified by each TSO but not more than 60 minutes
<b>Great Britain</b>	0,90 pu-1,05 pu	Unlimited
	1,05 pu-1,10 pu	15 minutes
<b>Ireland and Northern Ireland</b>	0,90 pu-1,05 pu	Unlimited
<b>Baltic</b>	0,90 pu-1,097 pu	Unlimited
	1,097 pu-1,15 pu	20 minutes

---

**Status:** Point in time view as at 31/12/2020.

**Changes to legislation:** There are outstanding changes not yet made to Commission Regulation (EU) 2016/1388. Any changes that have already been made to the legislation appear in the content and are referenced with annotations. (See end of Document for details)

---

The table shows the minimum time periods during which a transmission-connected demand facility, a transmission-connected distribution facility or a transmission-connected distribution system has to be capable of operating for voltages deviating from the reference 1 pu value at the connection point without disconnecting from the network, where the voltage base for pu values is from 300 kV to 400 kV (including).

**Status:**

Point in time view as at 31/12/2020.

**Changes to legislation:**

There are outstanding changes not yet made to Commission Regulation (EU) 2016/1388. Any changes that have already been made to the legislation appear in the content and are referenced with annotations.