

Commission Regulation (EU) 2017/1485 of 2 August 2017 establishing a guideline on electricity transmission system operation (Text with EEA relevance)

PART IV

LOAD-FREQUENCY CONTROL AND RESERVES

TITLE 2

FREQUENCY QUALITY

Article 130

Frequency quality evaluation data

- 1 The frequency quality evaluation data shall be:
 - a for the synchronous area:
 - (i) the instantaneous frequency data; and
 - (ii) the instantaneous frequency deviation data;
 - b for each LFC block of the synchronous area, the instantaneous FRCE data.
- 2 The measurement accuracy of the instantaneous frequency data and of the instantaneous FRCE data, where measured in Hz, shall be 1 mHz or better.

Changes to legislation:

Commission Regulation (EU) 2017/1485, Article 130 is up to date with all changes known to be in force on or before 10 June 2024. There are changes that may be brought into force at a future date. Changes that have been made appear in the content and are referenced with annotations.

[View outstanding changes](#)

Changes and effects yet to be applied to the whole legislation item and associated provisions

- Art. 2(3A) inserted by [S.I. 2019/533 Sch. 1 para. 3\(5\)](#) (This amendment not applied to legislation.gov.uk. Sch. 1 para. 3(5) omitted (15.9.2020) by virtue of S.I. 2020/1016, regs. 1(2), 6(3)(a))
- Art. 3.2(168) omitted by [S.I. 2024/706 reg. 44\(a\)\(iii\)](#)
- Art. 55(d) words inserted by [S.I. 2019/533 Sch. 1 para. 44\(2\)\(b\)](#) (This amendment not applied to legislation.gov.uk. Sch. 1 para. 44(2)(b) substituted (15.9.2020) by S.I. 2020/1016, regs. 1(2), 6(3)(j))