
STATUTORY RULES OF NORTHERN IRELAND

2000 No. 389

Building Regulations (Northern Ireland) 2000

PART E

Fire safety

Internal fire spread – Linings

- E3** To inhibit the spread of fire within a building the internal linings shall—
- (a) offer adequate resistance to the spread of flame over their surfaces; and
 - (b) where they are located in a circulation space, have a low rate of heat release when ignited.