#### STATUTORY RULES OF NORTHERN IRELAND

## 2000 No. 389

# Building Regulations (Northern Ireland) 2000

#### PART E

### Fire safety

#### Deemed-to-satisfy provisions for regulations E2, E3, E4, E5 and E6

- **E7.—**(1) The requirements of regulation E2 shall be deemed to be satisfied, in the case of a building specified in column (2) of Table E opposite the reference to that regulation, if the means of detection, giving warning and escape in the building are in accordance with the relevant provisions of the publications specified opposite thereto in column (3), as amended by the publications specified opposite thereto in column (4).
- (2) The requirements of regulation E3 shall be deemed to be satisfied, in the case of a building specified in column (2) of Table E opposite the reference to that regulation, if the internal linings used in the building are designed and constructed in accordance with the relevant provisions of the publications specified opposite thereto in column (3), as amended by the publications specified opposite thereto in column (4).
- (3) The requirements of regulation E4 shall be deemed to be satisfied, in the case of a building specified in column (2) of Table E opposite the reference to that regulation, if the building and measures to inhibit the spread of fire within it are in accordance with the relevant provisions of the publications specified opposite thereto in column (3), as amended by the publications specified opposite thereto in column (4).
- (4) The requirements of regulation E5 shall be deemed to be satisfied, in the case of a building specified in column (2) of Table E opposite the reference to that regulation, if the external walls and roof of the building are designed and constructed in accordance with the relevant provisions of the publications specified opposite thereto in column (3), as amended by the publications specified opposite thereto in column (4).
- (5) The requirements of regulation E6 shall be deemed to be satisfied, in the case of a building specified in column (2) of Table E opposite the reference to that regulation, if the facilities in and access to the building for the Fire Brigade are in accordance with the relevant provisions of the publications specified opposite thereto in column (3), as amended by the publications specified opposite thereto in column (4).