

---

STATUTORY RULES OF NORTHERN IRELAND

---

**2000 No. 389**

**Building Regulations (Northern Ireland) 2000**

**PART L**

**Heat-producing appliances and liquefied petroleum gas installations**

**Separation distances from an existing LPG storage tank**

**L5** A building shall be separated by a safe distance from any existing LPG storage tank within the same curtilage.