
STATUTORY RULES OF NORTHERN IRELAND

2004 No. 63

**Gas Safety (Installation and Use)
Regulations (Northern Ireland) 2004**

PART VII

MISCELLANEOUS

Escape of gas

37.—(1) Where any gas escapes from any pipe of a gas supplier or from any pipe, other gas fitting or gas storage vessel used by a person supplied with gas by a gas supplier, the supplier of the gas shall, within twelve hours of being so informed of the escape, prevent the gas escaping (whether by cutting off the supply of gas to any premises or otherwise).

(2) If the responsible person for any premises knows or has reason to suspect that gas is escaping into those premises, he shall immediately take all reasonable steps to cause the supply of gas to be shut off at such place as may be necessary to prevent further escape of gas.

(3) If gas continues to escape into those premises after the supply of gas has been shut off or when a smell of gas persists, the responsible person for the premises discovering such escape or smell shall immediately give notice of the escape or smell to the supplier of the gas.

(4) Where an escape of gas has been stopped by shutting off the supply, a person shall not cause or permit the supply to be re-opened (other than in the course of repair) until all necessary steps have been taken to prevent a recurrence of such escape.

(5) In any proceedings for an offence under paragraph (1) it shall be a defence for the supplier of the gas to prove that it was not reasonably practicable for him effectually to prevent the gas from escaping within the period of twelve hours referred to in that paragraph, and that he did effectually prevent the escape of gas as soon as it was reasonably practicable for him to do so.

(6) Nothing in paragraphs (1) and (5) shall prevent the supplier of the gas appointing another person to act on his behalf to prevent an escape of gas supplied by that supplier.

(7) Nothing in paragraphs (1) to (6) shall apply to an escape of gas from a network (within the meaning of regulation 2 of the Gas Safety (Management) Regulations (Northern Ireland) 1997⁽¹⁾) or from a gas fitting supplied with gas from a network.

(8) In this regulation any reference to an escape of gas from a gas fitting includes a reference to an escape or emission of carbon monoxide gas resulting from incomplete combustion of gas in a gas fitting, but, to the extent that this regulation relates to such an escape or emission of carbon monoxide gas, the requirements imposed upon a supplier by paragraph (1) shall, where the escape or emission is notified to the supplier by the person to whom the gas has been supplied, be limited to advising that person of the immediate action to be taken to prevent such escape or emission and the need for the examination and, where necessary, repair of the fitting by a competent person.

(1) S.R. 1997 No. 195

Status: This is the original version (as it was originally made). This item of legislation is currently only available in its original format.
