
STATUTORY RULES OF NORTHERN IRELAND

2012 No. 381

THE ELECTRICITY SAFETY, QUALITY
AND CONTINUITY REGULATIONS
(NORTHERN IRELAND) 2012

PART 5
OVERHEAD LINES

General restriction on the use of overhead lines

16.—(1) A generator or distributor shall not use any of their overhead lines (except those in generating stations and substations) which they know do not comply with this Part of these Regulations.

(2) An overhead line shall not be used for the purpose of supply at a nominal voltage greater than 400,000 volts.