

SCHEDULE 1

ACTIVITIES EXEMPT FROM WASTE MANAGEMENT LICENSING

- 10.—(1) Subject to sub paragraph (4)—
- (a) the reception and treatment within the curtilage of a water treatment works of any of the wastes listed in Table 4 if the total quantity of waste which is treated in any period of 12 months does not exceed 100,000 cubic metres; and
  - (b) the secure storage within the curtilage of a water treatment works of waste intended to be treated in reliance on the exemption conferred by paragraph (a).
- (2) Subject to the following provisions of this paragraph—
- (a) any recovery operation carried on within the curtilage of a sewage treatment works of any of the wastes listed in Table 4;
  - (b) the secure storage within the curtilage of a sewage treatment works of waste intended to be submitted to the activity mentioned in paragraph (a).

**Table 4**

<i>Codes</i> (1)	<i>Types of waste</i>
<i>Waste from waste water treatment plants not otherwise specified (19 08)</i>	
19 08 01	Screenings
19 08 05	Sludges from treatment of urban waste water
<i>Wastes from the preparation of water intended for human consumption or water for industrial use (19 09)</i>	
19 09 02	Sludges from water clarification
19 09 03	Sludges from decarbonation
19 09 06	Solutions and sludges from regeneration of ion exchangers
<i>Other municipal wastes (20 03)</i>	
20 03 04	Septic tank sludge

(1) Codes referred to in the European Waste Catalogue.

<i>Codes</i> (1)	<i>Types of waste</i>
20 03 99	Municipal waste not otherwise specified

(1) Codes referred to in the European Waste Catalogue.

(3) The total quantity of waste brought to a sewage treatment works for the purposes of a recovery operation in reliance upon the exemption covered by sub paragraph (2) in any period of 12 months shall not exceed 100,000 cubic metres.

(4) The area where a treatment or recovery operation takes place shall have an impermeable pavement capable of containing any spillage of waste received and connected to a drainage system with impermeable components which does not leak and which will ensure that—

- (a) no liquid will run off the pavement otherwise than via that system; and
- (b) except where they may be lawfully discharged, all liquids entering the system are collected in a sealed sump.