

SCHEDULE 2

Regulation 4(4)(d)

LABELLING OF DECONTAMINATED EQUIPMENT

Each item of decontaminated equipment must be clearly marked with an indelible and embossed or engraved sign which must include the following information:–

“DECONTAMINATED PCB EQUIPMENT

Fluid containing PCBs was replaced

- with ..... (name of the substitute)
- on ..... (date)
- by ..... (undertaking).

Concentration of PCBs in

- old fluid ..... % by weight
- new fluid ..... % by weight.