

SCHEDULE 1

PRESCRIBED CONCENTRATIONS AND VALUES

**Table D**

Microbiological and Chemical Parameters: Type B Supplies

**National Requirements**

<i>(1) Item</i>	<i>(2) Parameters</i>	<i>(3) Concentration or Value (maximum)</i>	<i>(4) Units of Measurement</i>
1.	Coliform Bacteria	0	number/100ml
2.	Conductivity (i)	2500	µS/cm at 20°C
3.	Enterococci	0	number/100ml
4.	Escherichia coli (E.coli)	0	number/100ml
5.	Hydrogen ion	9.5 6.5 (minimum)	pH value
6.	Lead	(a) 25, from 3/7/06 until 24/12/13  (b) 10, from 25/12/13	µgPb/l
7.	Nitrate	50	mgNO <sub>3</sub> /l
8.	Odour-qualitative		
9.	Taste-qualitative		
10.	Turbidity	4	NTU

Notes:

(i) The water should not be aggressive.

**Changes to legislation:**

There are currently no known outstanding effects for the The Private Water Supplies (Scotland) Regulations 2006, Table D .