

SCHEDULE 1

PRESCRIBED CONCENTRATIONS AND VALUES

Table D

Microbiological and Chemical Parameters: Type B Supplies

National Requirements

<i>(1)</i>	<i>(2)</i>	<i>(3)</i>	<i>(4)</i>
<i>Item</i>	<i>Parameters</i>	<i>Concentration or Value (maximum)</i>	<i>Units of Measurement</i>
1.	Coliform Bacteria	0	number/100ml
2.	Conductivity (i)	2500	µS/cm at 20°C
3.	Enterococci	0	number/100ml
4.	Escherichia coli (E.coli)	0	number/100ml
5.	Hydrogen ion	9.5	pH value
		6.5 (minimum)	
6.	Lead	(a) (a) 25, µgPb/l from 3/7/06 until 24/12/13 (b) 10, from 25/12/13	
7.	Nitrate	50	mgNO ₃ /l
8.	Odour-qualitative		
9.	Taste-qualitative		
10.	Turbidity	4	NTU

Notes:

(i) The water should not be aggressive.