

SCHEDULE 2

Regulations 21-23, 29 and 30

PARAMETERS, MONITORING AND SAMPLING FREQUENCIES

Table A

F1

<p>Textual Amendments</p> <p>F1 Sch. 2 Table A omitted (27.10.2017) by virtue of The Water Intended for Human Consumption (Private Supplies) (Scotland) Regulations 2017 (S.S.I. 2017/282), reg. 1(1), Sch. 10 para. 2(d)(xi) (with reg. 2)</p>
--

Table B

F2

<p>Textual Amendments</p> <p>F2 Sch. 2 Table B omitted (27.10.2017) by virtue of The Water Intended for Human Consumption (Private Supplies) (Scotland) Regulations 2017 (S.S.I. 2017/282), reg. 1(1), Sch. 10 para. 2(d)(xi) (with reg. 2)</p>
--

Table C

Routine Monitoring: Type B Supplies

Parameters

1. Coliform bacteria
2. Conductivity
3. Enterococci
4. *Escherichia coli* (E. coli)
5. Hydrogen ion
6. Lead
7. Nitrate(i)
8. Odour – qualitative(ii)
9. Taste – qualitative(ii)
10. Turbidity

Notes:

- (i) Samples need not be analysed for nitrate if there are reasonable grounds for believing that nitrate levels in the locality concerned are below 25 mg NO3/l.
- (ii) Samples should not be assessed qualitatively if there are reasonable grounds for suspecting that the water may give rise to a health hazard.

Changes to legislation:

There are currently no known outstanding effects for the The Private Water Supplies (Scotland) Regulations 2006, SCHEDULE 2.