

## SCHEDULE 2

### PARAMETERS, MONITORING AND SAMPLING FREQUENCIES

#### **Table C**

##### Routine Monitoring: Type B Supplies

###### Parameters

1. Coliform bacteria
2. Conductivity
3. Enterococci
4. *Escherichia coli* (E. coli)
5. Hydrogen ion
6. Lead
7. Nitrate(i)
8. Odour – qualitative(ii)
9. Taste – qualitative(ii)
10. Turbidity

###### Notes:

- (i) Samples need not be analysed for nitrate if there are reasonable grounds for believing that nitrate levels in the locality concerned are below 25 mg NO<sub>3</sub>/l.
- (ii) Samples should not be assessed qualitatively if there are reasonable grounds for suspecting that the water may give rise to a health hazard.