
SCOTTISH STATUTORY INSTRUMENTS

2006 No. 456

The Fire Safety (Scotland) Regulations 2006

PART III

FIRE SAFETY

Additional emergency measures in respect of dangerous substances

15.—(1) Subject to paragraph (4), in order to ensure the safety in respect of harm caused by fire of relevant persons arising from an accident, incident or emergency related to the presence of a dangerous substance in the relevant premises, the person with duties under section 53 or 54 must ensure that—

- (a) information on emergency arrangements is available, including—
 - (i) details of relevant work hazards and hazard identification arrangements; and
 - (ii) specific hazards likely to arise at the time of an accident, incident or emergency;
- (b) suitable warning and other communication systems are established to enable an appropriate response, including remedial actions and rescue operations, to be made immediately when such an event occurs;
- (c) where necessary, before any explosion conditions are reached, visual or audible warnings are given and relevant persons withdrawn; and
- (d) where the assessment indicates it is necessary, escape facilities are provided and maintained to ensure that, in the event of danger, relevant persons can leave endangered places promptly and safely.

(2) Subject to paragraph (4), the person with duties under section 53 or 54 must ensure that the information required by regulation 14(1)(a) and paragraph (1)(a) of this regulation, together with information on the matters referred to in paragraphs (1)(b) and (d) is—

- (a) made available to relevant accident and emergency services to enable those services, whether internal or external to the relevant premises, to prepare their own response procedures and precautionary measures; and
- (b) displayed at the relevant premises, unless the results of the assessment make this unnecessary.

(3) Subject to paragraph (4), in the event of a fire arising from an accident, incident or emergency related to the presence of a dangerous substance in the relevant premises, the person with duties under section 53 or 54 must ensure that—

- (a) immediate steps are taken to—
 - (i) mitigate the effects of the fire;
 - (ii) restore the situation to normal; and
 - (iii) inform those relevant persons who may be affected; and
- (b) only those persons who are essential for the carrying out of repairs and other necessary work are permitted in the affected area and they are provided with—

(i) appropriate personal protective equipment and protective clothing; and
(ii) any necessary specialised safety equipment and plant,
which must be used until the situation is restored to normal.

(4) Paragraphs (1) to (3) do not apply where–

- (a) the results of the assessment show that, because of the quantity of each dangerous substance in the premises, there is only a slight risk to relevant persons; and
- (b) the measures taken by the person with duties under section 53 or 54 to comply with his or her duty under regulation 11 are sufficient to control that risk.

Commencement Information

11 Reg. 15 in force at 1.10.2006, see [reg. 1](#)

Changes to legislation:

There are currently no known outstanding effects for the The Fire Safety (Scotland) Regulations 2006, Section 15.