
SCOTTISH STATUTORY INSTRUMENTS

2015 No. 346

The Private and Public Water Supplies (Miscellaneous Amendments) (Scotland) Regulations 2015

PART 3

Amendment of Public Water Supplies (Scotland) Regulations 2014

Amendment of Schedule 1

16. In Schedule 1 (prescribed concentrations and values) to the 2014 Regulations—

- (a) in Part 2 of Table C (indicator parameters)—
- (i) in the entry for item 14 (indicative dose), omit “/year”;
 - (ii) after that entry, insert—

“14A.	Radon ^(e)	100	Bq/l	Supply point ^(b) ”; and
-------	----------------------	-----	------	------------------------------------

- (iii) in the entry for item 15 (tritium), after “Tritium” insert “^(f)”;
- (b) in the notes to Table C, after the note for “^(d)” insert—
- “(e) Remedial action is to be deemed justified on radiological protection grounds, without further consideration, where radon concentrations exceed 1,000 Bq/l.
 - (f) If the concentration of tritium exceeds this value, an analysis of the presence of other artificial radionuclides must be also carried out by Scottish Water.”; and
- (c) after Table C (and the notes to that table), omit the definition of “Indicative dose”.

Status:

Point in time view as at 28/11/2015.

Changes to legislation:

There are currently no known outstanding effects for the The Private and Public Water Supplies (Miscellaneous Amendments) (Scotland) Regulations 2015, Section 16.