
Status: Point in time view as at 01/08/2012. This version of this cross heading contains provisions that are not valid for this point in time.
Changes to legislation: There are currently no known outstanding effects for the Flood and Water Management Act 2010, Paragraph 17. (See end of Document for details)

SCHEDULES

SCHEDULE 4

RESERVOIRS

VALID FROM 30/07/2013

High-risk reservoirs: monitoring and supervision

- 17 (1) Section 12 (supervision) is amended as follows.
- (2) In subsection (1) for “large raised reservoir” substitute “ high-risk reservoir ”.
- (3) After subsection (2) insert—
- “(2A) The supervising engineer must provide the undertaker with a written statement of any steps taken to maintain the reservoir in accordance with the recommendations of the inspecting engineer under section 10(3)(b).
- (2B) The engineer must provide a statement under subsection (2A) at least once every 12 months.”
- (4) In subsection (4) for “large raised reservoir” substitute “ high-risk reservoir ”.
- (5) At the end add—
- “(6) The supervising engineer may direct the undertaker to carry out a visual inspection of the reservoir at specified intervals for the purpose of identifying anything that might affect the safety of the reservoir.
- (7) The undertaker must notify the supervising engineer of—
- (a) each visual inspection that is carried out, and
- (b) anything noticed in the course of it.
- (8) The Minister may issue guidance about supervision in accordance with this section (and may take compliance into account when making decisions under section 4).”
- (6) In section 20(4) (reports, certificates etc.) after paragraph (e) add—
- “(f) any written statement given under section 12(2) or (2A);
- (g) any direction given under section 12(6);”

Status:

Point in time view as at 01/08/2012. This version of this cross heading contains provisions that are not valid for this point in time.

Changes to legislation:

There are currently no known outstanding effects for the Flood and Water Management Act 2010, Paragraph 17.