
STATUTORY INSTRUMENTS

1989 No. 635

The Electricity at Work Regulations 1989

PART II

GENERAL

Means for protecting from excess of current

11. Efficient means, suitably located, shall be provided for protecting from excess of current every part of a system as may be necessary to prevent danger.

Commencement Information

11 [Reg. 11](#) in force at 1.4.1990, see [reg. 1](#)

Changes to legislation:

There are currently no known outstanding effects for the The Electricity at Work Regulations 1989, Section 11.