
STATUTORY INSTRUMENTS

1995 No. 743

**The Offshore Installations (Prevention of Fire and
Explosion, and Emergency Response) Regulations 1995**

Control of emergencies

12. The duty holder shall—

- (a) take appropriate measures with a view to limiting the extent of an emergency, including such measures to combat fire and explosion; and
- (b) shall ensure that—
 - (i) where appropriate, those measures include provision for the remote operation of plant; and
 - (ii) so far as is reasonably practicable, any arrangements made and plant provided pursuant to this regulation are capable of remaining effective in an emergency.