

SCHEDULE 1

ADDITIONAL REQUIREMENTS

Ventilation of enclosed workplaces

6. If a mechanical ventilation system is used, it must be maintained in working order. Any breakdown must be indicated by a control system where this is necessary for the health of persons on the installation.