

SCHEDULE 2

REQUIREMENTS FOR WATER FITTINGS

Water system design and installation

- 13.** Every water system shall be tested, flushed and where necessary disinfected before it is first used.