

SCHEDULE 2

REQUIREMENTS FOR WATER FITTINGS

Hot water services

17.—(1) Every unvented water heater, not being an instantaneous water heater with a capacity not greater than 15 litres, and every secondary coil contained in a primary system shall—

- (a) be fitted with a vent pipe, a temperature control device, a temperature relief device and a combined temperature pressure and relief valve; or
- (b) be capable of accommodating expansion within the secondary hot water system.

(2) An expansion valve shall be fitted with provision to ensure that water is discharged in a correct manner in the event of a malfunction of the expansion vessel or system.