

SCHEDULE 2

REQUIREMENTS FOR WATER FITTINGS

Hot water services

20.—(1) No vent pipe from a primary circuit shall terminate over a storage cistern containing wholesome water for domestic supply or for supplying water to a secondary system.

(2) No vent pipe from a secondary circuit shall terminate over any combined feed and expansion cistern connection to a primary circuit.