

## **SCHEDULE 2**

### **REQUIREMENTS FOR WATER FITTINGS**

#### *Hot water services*

**24.** No supply pipe or secondary circuit shall be permanently connected to a closed circuit for filling a heating system unless it incorporates a backflow prevention device in accordance with a specification approved by the regulator for the purposes of this schedule.

**Changes to legislation:**

There are currently no known outstanding effects for the The Water Supply (Water Fittings) Regulations 1999, Paragraph 24.