
STATUTORY INSTRUMENTS

2001 No. 1140

The Climate Change Levy (Combined Heat and Power Stations) Prescribed Conditions and Efficiency Percentages Regulations 2001

Method of calculating efficiency percentages

4. The efficiency percentage of a combined heat and power station for the purposes of paragraph 15 of the Act is calculated by multiplying by 100 the fraction—

- (a) whose numerator is the station's total annual power output measured in megawatt hours; and
- (b) whose denominator is the station's total annual fuel energy input measured in megawatt hours,

as stated in its CHPQA certificate.