
STATUTORY INSTRUMENTS

2002 No. 2665

The Electricity Safety, Quality and Continuity Regulations 2002

PART VII

SUPPLIES TO INSTALLATIONS AND TO OTHER NETWORKS

Precautions against supply failure

23.—(1) A distributor shall ensure that his network shall be—

- (a) so arranged; and
- (b) so provided, where necessary, with fuses or automatic switching devices, appropriately located and set,

as to restrict, so far as is reasonably practicable, the number of consumers affected by any fault in his network.

(2) Subject to regulation 29, a distributor shall at all times take all reasonably practicable steps to avoid interruptions of supply resulting from his own acts.