

---

STATUTORY INSTRUMENTS

---

**2002 No. 2665**

The Electricity Safety, Quality and Continuity Regulations 2002

PART I

INTRODUCTORY

**Inspection of networks**

5. A generator or distributor shall, so far as is reasonably practicable, inspect his network with sufficient frequency so that he is aware of what action he needs to take so as to ensure compliance with these Regulations and, in the case of his substations and overhead lines, shall maintain for a period of not less than 10 years a record of such an inspection including any recommendations arising therefrom.