

---

STATUTORY INSTRUMENTS

---

**2006 No. 1679**

**The Measuring Instruments (Active  
Electrical Energy Meters) Regulations 2006**

**PART 2**

**PLACING ON THE MARKET AND PUTTING INTO  
USE OF ACTIVE ELECTRICAL ENERGY METERS**

**Marking and identification requirements**

- 12.**—(1) Where a relevant instrument is compliant with the essential requirements—
- (a) the manufacturer shall affix the CE mark and the M mark to the instrument; and
  - (b) the notified body which carries out the conformity assessment procedure in respect of that instrument shall affix its identification number to the instrument, or may agree that the manufacturer shall do so on its behalf.
- (2) Any other marking may be affixed to the relevant instrument provided that the visibility and legibility of the CE marking, the M marking and the identification number of the notified body are not reduced.
- (3) For the purposes of paragraph (1)—
- (a) the CE marking means the symbol “CE”, which shall be compliant with the requirements of paragraphs 1, 4 and 5 of Schedule 4;
  - (b) the M marking means the capital letter “M” which shall be compliant with the requirements of paragraphs 2, 4 and 5 of Schedule 4; and
  - (c) the identification number of the notified body shall be compliant with the requirements of paragraphs 3, 4 and 5 of Schedule 4.