

SCHEDULE 2

Monitoring

PART 2

Audit monitoring

Frequency of sampling

4.—(1) Sampling must be carried out at the frequencies specified in Table 3.

Table 3
Sampling frequency for audit monitoring

<i>Volume m³/day</i>	<i>Sampling frequency per year</i>
≤ 10	1
$> 10 \leq 3,300$	2
$> 3,300 \leq 6,600$	3
$> 6,600 \leq 10,000$	4
$> 10,000 \leq 100,000$	3 + 1 for each 10,000 m ³ /day of the total volume (rounding up to the nearest multiple of 10,000 m ³ /day)
$> 100,000$	10 + 1 for each 25,000 m ³ /day of the total volume (rounding up to the nearest multiple of 25,000 m ³ /day)

(2) The local authority may set a higher frequency for any parameter if it considers it appropriate taking into account the findings of any risk assessment.