

## SCHEDULE 2

### DANGEROUS OCCURRENCES

#### PART 1

#### GENERAL

##### **Electrical incidents causing explosion or fire**

4. Any explosion or fire caused by an electrical short circuit or overload (including those resulting from accidental damage to the electrical plant) which either—
  - (a) results in the stoppage of the plant involved for more than 24 hours; or
  - (b) causes a significant risk of death.