

## SCHEDULE 2

### Petrol Storage in Domestic or Other Relevant Premises

#### **Requirements for keeping up to 30 litres of petrol in suitable portable containers or in a single demountable fuel tank**

1. A person keeps petrol in accordance with this paragraph if—
  - (a) no more than a total of 30 litres in suitable portable containers or in a single demountable fuel tank is kept, of which—
    - (i) no more than 30 litres is kept in one or more suitable portable containers;
    - (ii) no more than 30 litres is kept in one demountable fuel tank; or
    - (iii) no more than 30 litres is kept in no more than two suitable portable containers in any motor vehicle, motor boat, hovercraft or aircraft;
  - (b) the storage place is—
    - (i) within, above, below, attached to, or within the curtilage of a building (but, subject to paragraphs (ii) and (iii), not a flat or public building);
    - (ii) below a flat;
    - (iii) attached to a public building; or
    - (iv) in a vehicle for the purpose of using it as fuel for any internal combustion engine;
  - (c) the storage place, where it is—
    - (i) within a building, is fire-separated from the rest of the building and any exit route from the building; and
    - (ii) above, below or attached to a building, is fire-separated from the building; and
  - (d) the common storage requirements of paragraph 3 are met.