

SCHEDULE 1

Safety Requirements

Requirements of a system of connected acetylene equipment

5. A system of connected acetylene equipment may only be used if the internal diameter of the pipework does not exceed the maximum diameter specified in the Table for the respective pressure of the compressed acetylene gas in use.