

SCHEDULE 1

Authorised project

PART 3

Requirements

Design approval onshore

10.—(1) No part of Work No. 25 shall commence until details of its layout, design, scale and external appearance (which shall accord with the principles of the onshore substation design and access statement) have been submitted to and approved in writing by West Sussex County Council.

(2) No building comprised in Work No. 25 shall exceed 6 metres in height above existing ground level and nor shall it exceed a footprint of 560m².

(3) No external equipment comprised in Work No. 25 shall exceed 10.5 metres in height above existing ground level.