

SCHEDULE 1

Prescribed concentrations or values

PART 2

Indicator parameters (excluding radioactive substances)

Table C

Prescribed concentrations, values or states

<i>Parameters</i>	<i>Maximum concentration or value or state (unless otherwise stated)</i>	<i>Units of measurement</i>
Ammonium	0.50	mg/l
Chloride ¹	250	mg/l
<i>Clostridium perfringens</i> (including spores)	0	Number/100ml
Coliform bacteria	0	Number/100ml (Number/250 ml in the case of water put into bottles of containers)
	F1	F2

Colony counts	No abnormal change	Number/ml at [^{F3} 22°C]
Conductivity ¹	2500	µS/cm at 20°C
Hydrogen ion	9.5 (maximum) 6.5 (minimum) (in the case of still water put into bottles or containers the minimum is 4.5)	pH value pH value
Sulphate ¹	250	mg/l
Total organic carbon (TOC)	No abnormal change	mgC/l
Turbidity ²	1	NTU

¹ The water should not be aggressive.² Only in the case of surface water or groundwater that has been influenced by surface water.**Textual Amendments**

- F1** Words in Sch. 1 Pt. 2 omitted (11.7.2018) by virtue of [The Private Water Supplies \(England\) \(Amendment\) Regulations 2018 \(S.I. 2018/707\)](#), regs. 1(1), **2(9)(b)(i)(aa)** (with reg. 3)
- F2** Words in Sch. 1 Pt. 2 omitted (11.7.2018) by virtue of [The Private Water Supplies \(England\) \(Amendment\) Regulations 2018 \(S.I. 2018/707\)](#), regs. 1(1), **2(9)(b)(i)(bb)** (with reg. 3)

Status: Point in time view as at 11/07/2018.

Changes to legislation: There are currently no known outstanding effects for the The Private Water Supplies (England) Regulations 2016, PART 2. (See end of Document for details)

F3 Word in Sch. 1 Pt. 2 substituted (11.7.2018) by The Private Water Supplies (England) (Amendment) Regulations 2018 (S.I. 2018/707), regs. 1(1), **2(9)(b)(ii)** (with reg. 3)

Status:

Point in time view as at 11/07/2018.

Changes to legislation:

There are currently no known outstanding effects for the The Private Water Supplies (England) Regulations 2016, PART 2.